

**FORM B**

[See section 3(3) and rule 4(2)]

**Six monthly Certificate to be given in every January and June by the occupier for compliance of the Fire prevention and life safety measures.**

**CERTIFICATE**

Certified that I/we have carried out inspection of the Fire prevention and life safety measures installed in the following building or premises, namely :-

**M/S. MACROTECH POLYCHEM PVT LTD**

Plot No. L-60/61, MIDC Tarapur, Industrial Area,  
Boisar, Tal - Dist-Palghar – 401506.

I/we further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period January 2025 to June 2025 as required under the provision of the Maharashtra Fire Prevention And Life Safety Measures Act, 2006 (Mah. III of 2007). The details of the inspection of installation carried out by me/us are mentioned in the report appended herewith.

**Details of inspection and maintenance/servicing are as per attached list.**

Place : Boisar

Authorized Signature

Address of Licensed Agency : L-3 Sundaram Apartment,  
Ostwal Empire Boisar 401506.

License no: - MFS/LA/RF-73

License no: - MFS/LA/D - 499



Contact No. 02525-267454  
Contact No. 9823162689 / 7875293195  
9764114418 / 9423371278



Gmail :- [newaimfireservice2010@gmail.com](mailto:newaimfireservice2010@gmail.com)



Work :- Street - I, Awadh Nagar, Navapur Road,  
Boisar 401506, Dist Palghar  
Office :- Bldg No L-3, Sundaram Apartment,  
Ostwal Empire, Boisar 401506, Dist Palghar

ANNEXURE

REF: NAFS/F-B /25-26/26/07/114

Date: 26/07/2025

**M/S. MACROTECH POLYCHEM PVT LTD**

Plot No. L-60/61, MIDC Tarapur, Industrial Area,

Boisar, Tal - Dist-Palghar – 401506.

**Annexure to Form B**

**1. System Statement for the Fire Extinguishers, Fire Alarm System & Fire Hydrant System.**

Sr. No.	Description	Qty
<b>A.</b>	<b>Fire Hydrant System</b>	
01.	Main Fire Pump 2280 LPM At 65 Mtrs, Head	01 Nos.
02.	Jockey Pump 180 LPM At 65 Mtrs, Head	01 Nos.
03.	Diesel Engine Driven Pump 2280 LPM At 65 Mtrs.	01 Nos.
04.	Single Stage Monoblock Centrifugal Booster Pump	01 Nos.
05.	Hydrant Valve	13 Nos.
06.	Underground Water Tank 3,00,000 Ltr.	01 Nos.
07.	Hose Box Double Door	07 Nos.
08.	Hose Box Single Door	06 Nos.
09.	Hydrant Hose 15 Mtrs Length	20 Nos.
10.	Hose Reel with Hose Pipe with Shut off Nozzle 20 MM	06 Nos.
11.	4 Way Fire Brigade Inlet	01 Nos.
<b>B.</b>	<b>Sprinkler System</b>	
01.	Main Fire Pump Sprinkler 2280 LPM At 65 Mtrs, Head	01 Nos.
02.	Jockey Pump Sprinkler 180 LPM At 65 Mtrs, Head	01 Nos.
03.	Pendent Type Sprinkler Head	74 Nos.
04.	Upright Type Sprinkler Head	115 Nos.
05.	Side Wall Type Sprinkler Head	22 Nos.
<b>C.</b>	<b>Fire Alarm System</b>	
01.	Fire Alarm Control Panel Four Loop	01 Nos.
02.	Smoke Detector	82 Nos.
03.	Hooter	06 Nos.
04.	Manual Call Point	03 Nos.
05.	Flame Proof Heat Detectors	75 Nos.
06.	Flame Proof Hooter	09 Nos.
07.	Flame Proof Manual Call Point	05 Nos.
<b>D.</b>	<b>Fire Extinguishers</b>	



Contact No. 02525-267454  
Contact No. 9823162689 / 7875293195  
9764114418 / 9423371278



Gmail :- newaimfireservice2010@gmail.com



Work :- Street - I, Awadh Nagar, Navapur Road,  
Boisar 401506, Dist Palghar  
Office :- Bldg No L-3, Sundaram Apartment,  
Ostwal Empire, Boisar 401506, Dist Palghar

01.	ABC Stored Pressure Powder Type Fire Extinguishers Capacity 5 Kg.	05 Nos.
02.	ABC Stored Pressure Powder Type Fire Extinguishers Capacity 6 Kg.	38 Nos.
03.	CO2 Type Fire Extinguishers Capacity 4.5 Kg	11 Nos.
04.	CO2 Type Fire Extinguishers Capacity 22.5 Kg	01 Nos.
05.	Mechanical Foam Store Pressure Type Fire Extinguishers Capacity 9 Ltrs.	12 Nos.
06.	Mechanical Foam Store Pressure Type Fire Extinguishers Capacity 50 Ltrs.	04 Nos.
<b>E.</b>	<b>Suppression System</b>	
01.	Aerosol Suppression System	04 Nos.
02.	Smoke Detector	08 Nos.
03.	Heat Detector	08 Nos.
04.	2 Zone Suppression Panel	04 Nos.
05.	Panel Battery Backup	04 Nos.
06.	Manual Call Point	04 Nos.
07.	Manual Release Switch	04 Nos.
08.	Manual Abort Switch	04 Nos.
09.	Hooter	08 Nos.
10.	Sequential Activator	01 Nos.
11.	SMPS	03 Nos.

Authorized Signature



Contact No. 02525-267454  
 Contact No. 9823162689 / 7875293195  
 9764114418 / 9423371278



Gmail :- [newaimfireservice2010@gmail.com](mailto:newaimfireservice2010@gmail.com)



Work :- Street - I, Awadh Nagar, Navapur Road,  
 Boisar 401506, Dist Palghar  
 Office :- Bldg No L-3, Sundaram Apartment,  
 Ostwal Empire, Boisar 401506, Dist Palghar